

### EXHIBIT A

#### SEMINOLE COUNTY WATER AND WASTEWATER SERVICE CAPACITY GUIDELINES

#### A. Water Meter Sizes and ERC Factor

Meter Sizes	ERC Factor
3/4"	1
1"	3
1 1/2"	5
2"	8
3"	17
4"	30
6"	63
8"	80

Single family residences that require a meter size greater than 3/4" to maintain proper water pressure will be assessed one (1) ERC. The monthly basic service charge for water and wastewater service will be charged as a single family structure and one (1) unit or ERC.

#### B. Capacity Factors

Animal Kennels

<u>Unit</u>	Water gpd	Wastewater <u>gpd</u>
Dwelling Unit	350	300
Dwelling Unit	275	250
Dwelling Unit	335	300
Dwelling Unit	275	250
Dwelling Unit	335	300
	Dwelling Unit Dwelling Unit Dwelling Unit Dwelling Unit	UnitgpdDwelling Unit350Dwelling Unit275Dwelling Unit335Dwelling Unit275

Note: The above water consumption on multi-family units includes installation of irrigation meters. Multi-family units without irrigation meters will be assessed a higher usage to be determined by the Department Director.

<u>Church</u> Commercial	Per kennel/cage	20	20
	Per seat	3	3
Barber Shop/Beauty Salons (including pedicure stations) Bowling Alley	Per Operating Station Per Lane	75 100	75 100

## SEMINOLE COUNTY ADMINISTRATIVE CODE

<u>Establishment</u>	<u>Unit</u>	Water gpd	Wastewater gpd
Doctor and Dentist Offices			
	Per Practitioner Add: Per Employee	250 15	250 15
Food Services			
Restaurant/Cafeteria Restaurant (24 hour) Restaurant (Fast Food) Bar/Cocktail Lounge	Per Seat Per Seat Per Seat Per Seat	30 50 25 30	30 50 25 30
Industrial Building			
(with showers) (without showers)	Per employee Per employee	25 15	25 15
<u>Hospital</u>			
	Per Bed	200	200
Hotel/Motel			
(without food services)	Per Bed	100	100
Laundry			
Self service	Per Machine	400	400
Nursing Home			
	Per bed	100	100
Office Buildings/Shopping Centers			
(without food service)	Per Sq. Ft.	0.1	0.1
Schools			
Day Type Boarding	Per Student Per Student	15 75	15 75
Service Station			
	Per Bay Per Wash Bay Per Toilet Room	300 960 300	300 960 300

# SEMINOLE COUNTY ADMINISTRATIVE CODE

<u>Establishment</u>	<u>Unit</u>	Water <u>gpd</u>	Wastewater <u>gpd</u>
<u>Stores</u>			
	Per square foot	0.1	0.1
Theater			
	Per Seat	5	5
<u>Trailer Park (overnight)</u>			
(with water/wastewater hook-up) (without water/wastewater hook-up)	Per space Per space	75 50	75 50
Warehouse			
	Per square foot	0.04	0.04